


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761 • Phone (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING



IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued To:

AYRLETT LLC

1424 FIRST STREET SOUTH NAMPA, ID 83651 , United States

Product:

Fire Tests of Penetration Firestop Systems

Products are in compliance with the following standard(s)

ASTM E814-2013a (2017) and CAN/ULC S115.2011(R2016)

File Number: 13001

Effective Date: January 2021

Void After: January 2026*


Chairman, Product Certification Committee





Chief Technical Service Officer

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: AYRLETT LLC

Effective Date: January 2021

File Number: 13001

Product: Fire Tests of Penetration Firestop Systems

Void After: January 2026

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Products shall be permanently marked with the manufacturer's name or trademark and the appropriate certification mark.


Characteristics:

Fire rated outlet boxes to be installed in accordance with the manufacturer's installation instructions.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: AYRLETT LLC

Effective Date: January 2021

File Number: 13001

Product: Fire Tests of Penetration Firestop Systems

Void After: January 2026

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org


Models

Outlet Boxes WM/UI

Model Number	Description
FR2071	Small In One Fire Rated with Valve & CPVC Attachment
FR2072	Small In One Fire Rated with Valve & 1960 Attachment
FR2073	Small In One Fire Rated with Valve & Pex Attachment
FR2074	Small In One Fire Rated with Valve & MIP Attachment
FR2271	Small In One Fire Rated With Valve + Arrester & CPVC Attachment
FR2272	Small In One Fire Rated With Valve + Arrester & 1960 Attachment
FR2273	Small In One Fire Rated With Valve + Arrester & PEX Attachment
FR2274	Small In One Fire Rated With Valve + Arrester & MIP Attachment
FR2081/FRB081	Multi-Pro Fire Rated with Valve & CPVC Attachment
FR2082/FRB082	Multi-Pro Fire Rated with Valve & 1960 Attachment
FR2083/FRB083	Multi-Pro Fire Rated with Valve & Pex Attachment
FR2084/FRB084	Multi-Pro Fire Rated with Valve & MIP Attachment
FR2281/FRB281	Multi-Pro Fire Rated With Valve + Arrester & CPVC Attachment
FR2282/FRB282	Multi-Pro Fire Rated With Valve + Arrester & 1960 Attachment
FR2283/FRB283	Multi-Pro Fire Rated With Valve + Arrester & PEX Attachment
FR2284/FRB284	Multi-Pro Fire Rated With Valve + Arrester & MIP Attachment
FR2091/FRB091	Twin Box Fire Rated With Valve & CPVC Attachment
FR2092/FRB092	Twin Box Fire Rated With Valve & 1960 Attachment
FR2093/FRB093	Twin Box Fire Rated With Valve & Pex Attachment
FR2094/FRB094	Twin Box Fire Rated With Valve & MIP Attachment
FR2292/FRB292	Twin Box Fire Rated With Valve + Arrester & CPVC Attachment
FR2292/FRB292	Twin Box Fire Rated With Valve + Arrester & 1960 Attachment
FR2293/FRB293	Twin Box Fire Rated With Valve + Arrester & Pex Attachment
FR2294/FRB294	Twin Box Fire Rated With Valve + Arrester & MIP Attachment
FRPT-Box/FRAT-Box	Air Admittance Valve Box Fire Rated with Louvered Cover
FR3900	UI Box Fire Rated

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: AYRLETT LLC

Effective Date: January 2021

File Number: 13001

Product: Fire Tests of Penetration Firestop Systems


Void After: January 2026

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Model Number	Description
FR3901	Small In One Box Fire Rated
FR3902	Twin Box Fire Rated
FR3903	Utility Box Fire Rated
JBSFR2071	Small In One Fire Rated with Valve & CPVC Attachment
JBSFR2072	Small In One Fire Rated with Valve & 1960 Attachment
JBSFR2073	Small In One Fire Rated with Valve & Pex Attachment
JBSFR2074	Small In One Fire Rated with Valve & MIP Attachment
JBSFR2271	Small In One Fire Rated With Valve + Arrester & CPVC Attachment
JBSFR2272	Small In One Fire Rated With Valve + Arrester & 1960 Attachment
JBSFR2273	Small In One Fire Rated With Valve + Arrester & PEX Attachment
JBSFR2274	Small In One Fire Rated With Valve + Arrester & MIP Attachment
JBSFR2081/JBSFRB081	Multi-Pro Fire Rated with Valve & CPVC Attachment
JBSFR2082/JBSFRB082	Multi-Pro Fire Rated with Valve & 1960 Attachment
JBSFR2083/JBSFRB083	Multi-Pro Fire Rated with Valve & Pex Attachment
JBSFR2084/JBSFRB084	Multi-Pro Fire Rated with Valve & MIP Attachment
JBSFR2281/JBSFRB281	Multi-Pro Fire Rated With Valve + Arrester & CPVC Attachment
JBSFR2282/JBSFRB282	Multi-Pro Fire Rated With Valve + Arrester & 1960 Attachment
JBSFR2283/JBSFRB283	Multi-Pro Fire Rated With Valve + Arrester & PEX Attachment
BSFR2284/JBSFRB284	Multi-Pro Fire Rated With Valve + Arrester & MIP Attachment
JBSFR2091/JBSFRB091	Twin Box Fire Rated With Valve & CPVC Attachment
JBSFR2092/JBSFRB092	Twin Box Fire Rated With Valve & 1960 Attachment
JBSFR2093/JBSFRB093	Twin Box Fire Rated With Valve & Pex Attachment
JBSFR2094/JBSFRB094	Twin Box Fire Rated With Valve & MIP Attachment
JBSFR2292/JBSFRB292	Twin Box Fire Rated With Valve + Arrester & CPVC Attachment
JBSFR2292/JBSFRB292	Twin Box Fire Rated With Valve + Arrester & 1960 Attachment
JBSFR2293/JBSFRB293	Twin Box Fire Rated With Valve + Arrester & Pex Attachment
JBSFR2294/JBSFRB294	Twin Box Fire Rated With Valve + Arrester & MIP Attachment
JBSFRPT-Box/JBSFRAT-Box	Air Admittance Valve Box Fire Rated with Louvered Cover
JBSFR3900	UI Box Fire Rated

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: AYRLETT LLC

Effective Date: January 2021

File Number: 13001

Product: Fire Tests of Penetration Firestop Systems

Void After: January 2026

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Model Number	Description
JBSFR3901	Small In One Box Fire Rated
JBSFR3902	Twin Box Fire Rated
JBSFR3903	Utility Box Fire Rated
JBSFR4071	Fire Rated 3/8" Kitchen/Dishwasher Supply Box - CPVC
JBSFR4072	Fire Rated 3/8" Kitchen/Dishwasher Supply Box - F1960
JBSFR4073	Fire Rated 3/8" Kitchen/Dishwasher Supply Box - PEX
JBSFR4074	Fire Rated 3/8" Kitchen/Dishwasher Supply Box - MIP
JBSFR4271	Fire Rated 3/8" Kitchen/Dishwasher Supply Box w/ Arrester on DCT Valve Only - CPVC
JBSFR4272	Fire Rated 3/8" Kitchen/Dishwasher Supply Box w/ Arrester on DCT Valve Only - F1960
JBSFR4273	Fire Rated 3/8" Kitchen/Dishwasher Supply Box w/ Arrester on DCT Valve Only - PEX
JBSFR4274	Fire Rated 3/8" Kitchen/Dishwasher Supply Box w/ Arrester on DCT Valve Only - MIP
JBSFR4471	Fire Rated 3/8" Lavatory Outlet Box - CPVC
JBSFR4472	Fire Rated 3/8" Lavatory Outlet Box - F1960
JBSFR4473	Fire Rated 3/8" Lavatory Outlet Box - PEX
JBSFR4474	Fire Rated 3/8" Lavatory Outlet Box - MIP
JBSFR4671	Fire Rated 3/8" Toilet/Dishwasher Box - CPVC
JBSFR4672	Fire Rated 3/8" Toilet/Dishwasher Box - F1960
JBSFR4673	Fire Rated 3/8" Toilet/Dishwasher Box - PEX
JBSFR4674	Fire Rated 3/8" Toilet/Dishwasher Box - MIP
JBSFR4871	Fire Rated 3/8" Toilet/Dishwasher Box w/ Arrester - CPVC
JBSFR4872	Fire Rated 3/8" Toilet/Dishwasher Box w/ Arrester - F1960
JBSFR4873	Fire Rated 3/8" Toilet/Dishwasher Box w/ Arrester - PEX
JBSFR4874	Fire Rated 3/8" Toilet/Dishwasher Box w/ Arrester- MIP


***Fire Rated Plumbing Outlet Boxes were evaluated for conformance to ASTM E814, "Standard Method for Fire Tests of Through-Penetration Fire Stops" and achieved the following results:**

One Layer of 5/8 Gypsum
Wallboard:

Wall Assembly: 1 Hours, "F" Rating: 1 Hours, "T" Rating: 32 Minutes

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: AYRLETT LLC

Effective Date: January 2021

File Number: 13001

Product: Fire Tests of Penetration Firestop Systems

Void After: January 2026

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Two Layers of 5/8 Gypsum
Wallboard:

Wall Assembly: 2 Hours, "F" Rating: 2 Hours, "T" Rating: 66 minutes

***Fire Rated Plumbing Outlet Boxes were evaluated for conformance to CAN/ULC S115, "Standard Method of Fire Tests of Firestop Systems" and achieved the following results:**

One Layer of 5/8 Gypsum
Wallboard:

Wall Assembly: 1 Hours, "FH" Rating: 1 Hours, "FT" Rating: 32 Minutes

One Layers of 5/8 Gypsum
Wallboard:

Wall Assembly: 2 Hours, "FH" Rating: 2 Hours, "FT" Rating: 66 minutes